



Certificate of Compliance

This certificate is issued for the following:

**Plastic Pipe and Fittings for Wet Pipe Automatic Sprinkler Systems
in HC-1 Occupancies**

**Rotoplas Tuboplus PP-R CT Pipe and Fittings
SDR 11 PP-R CT Pipe and Fittings
Sizes 25 through 125 mm (External Diameter)**

Prepared for:

Rotoplas
Calle Anáhuac 91, El Mirador
Coyocan, Ciudad de Mexico, 04950
Mexico

FM Approvals Class: 1635

Approval Identification: PR461220

Approval Granted: October 7, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D. B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

